certifire

CERTIFICATE OF APPROVAL No CF 6114

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products The undermentioned products of

JELD-WEN UK Ltd RETFORD ROAD, WOODHOUSE MILL, SHEFFIELD, S13 9WH Tel: 0345 122 2891

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

CERTIFIED PRODUCT 44 mm Secureset PAS24 Timber Doorset TECHNICAL SCHEDULE TS10 Fire Resisting Door Assemblies with Non Metallic Leaves

Enhanced Security certified to STS201 under CERTISECURE certificate CS 5145

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan Certification Manager

Issued: Audit Test Frequency: Valid to: 07th January 2025 Every 5 years 06th January 2030





EWC-QU-FT-733 (Issue 2)

Page 1 of 3

This certificate is the property of Warringtonfire Testing and Certification Limited Registered in England and Wales Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

certifire

CERTIFICATE No CF 6114 JELD-WEN UK Ltd

JELD-WEN UK LIMITED - 44 mm Secureset PAS24 Timber Doorset

This approval relates to the use of the above doorsets in providing fire resistance of 30 minutes insulation and 30 minutes integrity as defined in BS 476: Part 22: 1987. Subject to the undermentioned conditions, the doorsets would be expected to meet the relevant requirements of BS 9999 for 30 minute doorsets when used in accordance with the provisions therein.

The doorset designs described in this certificate could therefore be given an 'FD30' notation, as defined in BS 8214: 2016. Please note the 'FD' notation only indicates integrity performance to BS 476: Part 22: 1987. Specific performance requirements for doorsets are set out in the relevant building regulations.

- 1. This certification is provided to the client for their own purposes, and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 2. The doorsets are approved on the basis of:
 - i) Initial type testing
 - ii) A design appraisal against TS10
 - iii) Inspection and surveillance of factory production control
 - iv) Certification under a CERTIFIRE approved Quality Management System
 - v) Audit testing in accordance with TS10
- 3. The doorsets comprise cellulosic laminated cored, timber leaves, for use with timber frames, with intumescent edge seals (code ITT FD30).
- 4. This approval is applicable to complete doorsets. It is a condition of this approval that an agreed Data Sheet accompanies the product and is complied with in its entirety. Failure to do so will invalidate this approval and may jeopardise the fire performance of the doorset.
- 5. This approval is applicable to single-acting, single-leaf, unglazed, latched open in (away from physical attack), ITT doorsets with or without coupled sidelights and toplights, at leaf dimensions up to those given in Table 1 & Table 2 below:

Doorset Configuration	Maximum Height (mm)	Maximum Width (mm)	Maximum Area (m²)
Single-Acting, Single-Leaf Latched – With/Without Sidelights/Toplights. Open in (away from attack)	2040	926	1.89
Table 1.			

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTIFIRE approval.

Signed EWC-QU-FT-733 (Issue 2) CLQ31793-2 Page 2 of 3

ligg-

Issued: 07th January 2025 Valid to: 06th January 2030

certifire

CERTIFICATE No CF 6114 JELD-WEN UK Ltd

JELD-WEN UK LIMITED - 44 mm Secureset PAS24 Timber Doorset

Doorset	Maximum Frame Height	Maximum Frame Width
Configuration	(mm)	(mm)
Single-Acting, Single-Leaf Latched <u>Without Sidelights and Toplights</u> <u>Open in (away from attack)</u>	2100	1000
Single-Acting, Single-Leaf Latched <u>With Sidelights and Toplights</u> * Open in (away from attack)	2600	2600
Table 2.		

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTIFIRE approval.

*Ensuring maximum leaf and glass sizes are not exceeded

- 6. Glazing shall not be included within door leaves.
- 7. Hardware items, including closing devices and intumescent fire seals, shall as specified in the Data Sheet.
- 8. The doorsets shall be mechanically fixed to wall constructions having a fire resistance of at least 30 minutes.
- Labels to the CERTIFIRE/CERTISECURE design referencing CERTIFIRE, CERTISECURE, PAS24 D, JELD-WEN UK Ltd, CERTIFIRE certificate No. CF 6114 and CERTISECURE certificate No. CS 5145 shall be affixed to each doorset in the prescribed position.
- 10. This approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application when appropriate.

Signed EWC-QU-FT-733 (Issue 2) CLQ31793-2 Page 3 of 3

ful ligg-

Issued: 07th January 2025 Valid to: 06th January 2030

CF 6114 DATA SHEET

1. <u>General</u>

This doorset has been fire tested and is certified by CERTIFIRE as being capable of providing fire resistance of 30 minutes integrity and 30 minutes insulation as defined in BS 476: Part 22: 1987, when installed in accordance with the following conditions. Subject to these, the doorset will meet the relevant requirements of BS 9999 for 30 minutes when used in accordance with the provisions therein.

The doorset designs described in this certificate could therefore be given an 'FD30' notation, as defined in BS 8214: 2016. Please note the 'FD' notation only indicates integrity performance to BS 476: Part 22: 1987. Specific performance requirements for doorsets are set out in the relevant building regulations

In recognition of this, the leaf carries a prefixed label on the top or hanging edge of the door, issued under the terms of the CERTIFIRE scheme. This label uniquely identifies the doorset, the manufacture of which complies with a CERTIFIRE approved Quality Management System and is subject to ongoing surveillance. **This label shall not be removed.**

It is emphasised that the certification is conditional upon the following instructions being complied with in their entirety. Failure to do so will invalidate this approval and may jeopardise the fire performance of the doorset. Doorsets supplied pre-fitted with components by Jeld-Wen UK Limited may be considered to meet the requirements in respect of those items.

2. Doorset Dimensions

This approval is applicable to single-action, single-leaf, latched, assemblies at leaf dimensions up to those detailed within Table 1 & Table 2 below:

Doorset	Maximum Height	Maximum Width	Maximum Area
Configuration	(mm)	(mm)	(m²)
Single-Acting, Single-Leaf Latched – With/Without Sidelights/Toplights Open in (away from attack)	2040	926	1.89

Table 1.

Doorset Configuration	Maximum Frame Height (mm)	Maximum Frame Width (mm)
Single-Acting, Single-Leaf Latched <u>Without Sidelights and Toplights</u> Open in (away from attack)	2100	1000
Single-Acting, Single-Leaf Latched <u>With Sidelights and Toplights</u> * Open in (away from attack)	2600	2600
	Table 2.	

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTIFIRE approval.

*Ensuring maximum leaf and sidelight/toplight glass sizes and overall glazing edge perimeter of 16.48 are not exceeded

Page 1 of 11 January 2025 warringtonfire

3. Door Frame

To be in accordance with the following specification:

Option 1	
Material	Softwood (solid or clear engineered tri-laminated and finger jointed material)
Density:	500 kg/m ³ minimum
Dimensions:	66 mm wide by 52 mm thick with a 48 mm wide by 20 mm deep rebate.

Option 2		
Material	Hardwood (solid)	
Density:	500 kg/m ³ minimum	
Dimensions:	66 mm wide by 52 mm thick with a 48 mm wide by 20 mm deep rebate.	

All frames will comply with the following requirements:

Jointing:	Mortice and tenon joint, screwed, and glued, screw fixed with two Ø5 mm by 70 mm hardened single thread woodscrew		70
Door to frame	Top and vertical edges	Not to exceed 4 mm.	
gaps:	Threshold – <u>With</u> LAS8001SI dropseal	Not to exceed 8 mm.	

4. Overpanels / Sidepanels

Not permitted.

5. Glazed Toplights & Sidelights

Toplight / Sideli	ght Framing:
Manufacturer:	Jeld-Wen UK
Reference:	FD30 Head
Material:	Softwood (solid or clear engineered tri-laminated and finger jointed material)
Density:	500 kg/m ³ minimum
Dimensions:	66 mm wide by 52 mm thick with a 48 mm wide by 20 mm deep rebate or 95 mm wide by 52 mm thick with a 48 mm wide by 20 mm deep rebate
Fixing method:	Mortice and tenon joint, screwed and glued using two Ø5 by 70 mm long hardened single thread woodscrews and HB Fuller Rakol Eco 3 Plus adhesive.
Sidelight Frami	ng – T Section:
Manufacturer:	Jeld-Wen UK
Reference:	FD30 T Head
Material:	Softwood (solid or clear engineered tri-laminated and finger jointed material)
Density:	500 kg/m ³ minimum
Dimensions:	48 mm wide by 70 mm thick with a 30 mm wide by 20 mm deep rebate or 77 mm wide by 70 mm thick with a 30 mm wide by 20 mm deep rebate.
Fixing method:	T-Section mulled to door frame and fixed into position using seven Ø4.2 mm by 38 mm long woodscrews at 300 mm centres, 100 mm from the corners.

Coupled Sidelight / Toplight Fixings:		
Supplier:	Timber Mate Fastners	
Description:	Pozi double CSK head wood screws	
Reference:	Woodscrews	
Dimensions:	Ø4.2 mm by 50 mm long	
Position:	Screwed at 300 mm centres, 100 mm from the corners.	

Sidelight Frame - Midrail:		
Manufacturer:	Jeld-Wen UK	
Reference:	FD30 direct mulled midrail sidelight	
Material:	Softwood (solid or clear engineered tri-laminated and finger jointed material)	
Density:	500 kg/m ³ minimum	
Dimensions:	66 mm wide by 150 mm thick with a 48 mm wide by 20 mm deep rebate.	
Fixing method:	Midrail butt jointed to mullion and frame, screwed and glued using two Ø4.2 mm by 70 mm long CSK woodscrews (each side) and HB Fuller Rakol Eco 3 Plus adhesive.	

Toplight / Sidelight – Glazing Option 1 – Insulated Glass			
Supplier:	CGI International		
Configuration:	Pyroguard T-EI30/16-1 VF		
	4 mm / 0.76 mm PVB / 4	4 mm.	
	Performance to EN356 I	P1A	
	5 mm gel layer		
	One 6 mm T-EI30 16-1	VF Fire glass	
Thickness:	19.76 mm nominal		
Maximum pane	Sidelight option 1:	2526 mm high by 480 mm wide (1.21 m ²)	
dimensions:	Sidelight option 2:	2020 mm high by 990 mm wide (2.00 m ²)	
	Toplight:	432 mm high by 1972 mm wide (0.85 m ²)	
	Subject to a maximum g	lazing edge perimeter of 16.48m	
Nominal edge clearance:	5 mm		
Setting Blocks:			
Supplier:	Ram Extrusions		
Reference:	Blue 60		
Description:	Glazing packers		
Dimensions:	One 5 mm by 100 mm by 15 mm – spaced approximately 200 mm from the corners.		
Glazing System:			
Supplier:	Sealmaster		
Description:	Intumescent closed cell tape – CF5645		
Reference:	CFT		
Dimensions:	15 mm by 3 mm		
Fixing method:	Self-adhesive, applied to rebate and glazing bead		

Page 3 of 11 January 2025 warringtonfire

Toplight / Sidelight – Glazing Option 2 – Non-Insulated Glass			
Supplier:	CGI International		
Configuration:	Pyroguard T-EW30/6 VF RV		
	6 mm / 0.76 mm PVB /		
	Performance to EN356	P1A	
Thickness:	12.76 mm nominal		
Maximum pane	Sidelight option 1:	2516 mm high by 470 mm wide (1.18 m ²)	
dimensions:	Sidelight option 2:	2010 mm high by 980 mm wide (1.97 m ²)	
	Toplight:	422 mm high by 1962 mm wide (0.83 m ²)	
	Subject to a maximum glazing edge perimeter of 16.48m		
Nominal edge clearance:	10 mm		
Setting Blocks:			
Supplier:	Ram Extrusions		
Reference:	Blue 60		
Description:	Glazing packers		
Dimensions:	Two 5 mm by 100 mm by 10 mm (to provide 10 mm packer depth) – spaced approximately 200 mm from the corners.		
Glazing System:			
Supplier:	Sealmaster		
Description:	Intumescent foam tape - CF5387		
Reference:	GTR		
Dimensions:	20 mm by 5 mm		
Fixing method:	Self-adhesive, applied to rebate and glazing bead		

Glazing Beads:	
Glazing method:	Externally beaded
Supplier:	Jeld-Wen UK
Reference:	Splayed flush bead
Material:	Red grandis hardwood
Density:	570 kg/m ³ minimum
Dimensions:	20 mm by 24 mm
Fixing method:	Ø4 mm by 40 mm long CS security screws, at maximum 150 mm centres, maximum 50 mm in from the corners.

6. <u>Supporting Construction</u>

The door assemblies are approved to be installed in brick, block, masonry, timber or steel stud supporting constructions of minimum overall thickness 85 mm, providing at least 30 minutes fire resistance and previously proven capable of supporting a fire door assembly for the required integrity performance.

JELD-WEN UK LTD Data Sheet CF6114 Page 4 of 11 January 2025 Where stud partitions are used these should be suitably constructed to provide a secure fixing for the door assemblies as recommended by the partition manufacturer.

Where brick, block, masonry walls are plasterboard faced, the plasterboard shall be mechanically fixed to ensure that it remains in-situ for the required integrity period.

7. Installation

The opening may be lined with softwood or hardwood which shall be continuous and of minimum width, 85mm. Each door frame jamb to be fixed through to the wall at not less than four points with steel or nylon fixings at maximum 600 mm centres penetrating the wall to at least 50 mm. Timber architraves are optional with no restrictions on material, size or fixing.

Doorsets shall be installed as stated in BS 8214. Suitable CERTIFIRE approved lineal gap sealing systems may also be utilised to protect the frame/supporting construction gap, subject to the conditions contained within the relevant certificate.

Plastic packers of varying thickness may be utilised at the frame fixing positions, subject to the packers being fully concealed by the application of a 10 mm deep intumescent mastic capping to both faces. Packers will be cut back as necessary to accommodate the 10 mm deep intumescent mastic capping required.

The use of third party accredited installers provides a means of ensuring that installations have been conducted by knowledgeable contractors, to appropriate standards, thereby increasing the reliability of the anticipated performance in fire.

On-site trimming of the door leaves is not permitted.

8. Glazed Apertures

Not permitted.

9. Intumescent Seals

CERTIFIRE certificated intumescent seals are required to be fitted to these doorsets as below.

For doorsets to BS476: Part 22 – 30 minutes integrity without sidelights & toplights.

Door Assembly Configuration*	Position	Required Intumescent Protection
Single-acting Single-leaf latched Without sidelights /	Frame head	Single 20 mm wide by 4 mm thick Lorient Polyproducts 'Type 617' Finesse seals positioned 11 mm from the opening face of the frame, within the frame reveal
Open in (away from attack)	Frame jambs	Single 20 mm wide by 4 mm thick Lorient Polyproducts 'Type 617' Finesse seals positioned 11 mm from the opening face of the frame, within the frame reveal

*See Table 1 for size restrictions

For doorsets to BS476: Part 22 – 30 minutes integrity with sidelights & toplights.

Door Assembly Configuration*	Position	Required Intumescent Protection
Single-acting	Frame head	Single 20 mm wide by 4 mm thick Lorient Polyproducts 'Type 617' Finesse seals positioned 11 mm from the opening face of the frame, within the frame reveal &
Single-leaf latched With sidelights /		Single 10 mm wide by 4 mm thick Lorient Polyproducts 'Type 617' Finesse seals positioned 35 mm from the opening face of the frame, within the frame reveal
toplights Open in (away from attack)	Frame jambs	Single 20 mm wide by 4 mm thick Lorient Polyproducts 'Type 617' Finesse seals positioned 11 mm from the opening face of the frame, within the frame reveal &
	,	Single 10 mm wide by 4 mm thick Lorient Polyproducts 'Type 617' Finesse seals positioned 35 mm from the opening face of the frame, within the frame reveal

*See Table 1 for size restrictions

Intumescent strips cannot be changed from the specific size, type and location specified in the tables above.

Intumescent seals interrupted at hinge and latch positions.

10. Door frame Seals

The Q-Lon seal referenced Aquamac 21 is required to be fitted within the frame jambs and head to all doorsets, mounted on the stop such that the perimeter of the door leaf face contacts the seal when the door is in the closed position.

The Aquamac 21 seal shall not be interrupted by the hardware.

11. Hinges

Hinges shall be CE marked against EN 1935 for use on 30 minute timber fire doorsets in accordance with the following specifications:

[
Supplier:	Zoo Hardware			
Description:	Grade 13 hinge			
Reference:	ZHSS243RS / ZH	ZHSS243RS / ZHSS243RP / ZHSS243RPVD		
Quantity:	3	3		
Hinge	Top hinge:	150 mm (+0/-50 mm) from top of door to top of hinge		
positions:	Middle hinge:	960 mm (± 50 mm) from top of door to top of hinge		
	Bottom hinge:	250 mm (+0/-50 mm) from bottom of door to bottom of hinge		
Dimensions:	Blade height:	102 mm		
	Blade width:	30.2 mm		
	Blade thickness:	3 mm (± 0.25 mm)		
	Knuckle Ø:	13 mm		
Fistingen	Quantity:	Four steel CSK wood screws per blade		
Fixings:	Size:	Ø4.9 mm by 32 mm long screws		
Intumescent	None required	·		
protection:				

12. <u>Locks</u>

Doorsets shall be fitted with a multipoint lock with a latch bolt to the central lock in accordance with the following specification options:

Supplier:	ERA Home Security		
Description:	Lock:	Invincible multipoint lock with 3 hook bolts	
	Keep set:	Invincible multipoint lock keep set	
Reference:	Lock:	6935-3H-609-79ZA (ERA Branding)	
		6935-3H-629-79ZJ (Jeld-Wen Branding)	
	Keep set:	5402-85RE (hook keeps)	
		6408-85-LH/RH (centre keep)	
Case dimensions:	Central:	226 mm high by 60 mm deep by 15 mm wide	
	Top & bottom:	110.5 mm high by 43 mm deep by 14.5 mm wide	
Keep dimension:	Central:	200 mm high by 22 mm wide	
	Top & bottom:	177 mm high by 35 mm wide	
Forend dimensions:	1635 mm high by 20 mm wide by 2.5 mm thick		
Latchbolt material:	Steel		
Position:	1015 mm from top of door to centreline of spindle		
Lock configuration:	Central:	Engaged latchbolt	
Intumescent	All lock cases:	Fully wrapped in 1 mm thick Interdens sheet material.	
protection:	Forend:	Bedded on 1 mm thick Interdens sheet material	
	All keeps:	Bedded on 1 mm thick Interdens sheet material (including under tongue to central keep and to rear of all dust boxes).	
Fixings:	Lock	Ten Ø3.9 mm by 64 mm long CSK steel wood screws	
	Central keep:	Three Ø3.9 mm by 32 mm CSK steel wood screws	
	Top & bottom keep:	Four Ø3.9 mm by 32 mm CSK steel wood screws	

Recessing for locks / forends / keeps shall result in a tight fit.

ERA Invincible locks shall be fitted with a cylinder in accordance with the following specification options:

Option 1		
Supplier:	Eurospec / Carlisle Brass	
Description:	TS007 1* Euro profile cylinder including key-key and key-thumbturn options	
Reference:	MPX6	
Certification reference:	KM585549	
Intumescent protection:	None required	
Fixings:	One M5 by 55 mm machine screw	
Note:	For use with handle option 1 only	

Page 7 of 11 January 2025 warringtonfire

Option 2			
Supplier:	ERA Home Security		
Description:	TS007 3* Fortress 3* cylinder		
Reference:	35/35 ERA 3* Fortress Cylinder including key-key and key-thumbturn options		
Certification reference:	KM553031		
Intumescent protection:	None required		
Fixings:	One M5 by 55 mm machine screw		
Note:	For use with handle option 2 only		

The Euro profile cylinder recess in the door face shall follow the shape of the cylinder and result in a tight fit.

Lever handles are required in accordance with the specification below:

Option 1	
Supplier:	Mila Hardware
Description:	ProSecure
Reference:	E Variant 92 PZ TS007 2*
Material:	Zinc alloy and steel
Overall size:	240 mm by 32 mm
Lever length:	126mm
Intumescent protection:	None required
Fixings:	Two M6 x 61mm machine screw
Note:	For use with cylinder option 1 only

Option 2	
Supplier:	ERA Home Security / Fab & Fix
Description:	Balmoral handle
Reference:	Fab & Fix Balmoral Inline Lever
Material:	Zinc for Hardex finishes or Aluminium for white, black & silver finishes
Overall size:	243 mm by 32 mm
Lever length:	120mm
Intumescent protection:	None required
Fixings:	Two M5 x 70mm, and two M5 x 80mm machine screws
Note:	For use with cylinder option 2 only

Page 8 of 11 January 2025 warringtonfire

13. Self-Closing Devices

Doorsets shall be fitted with a concealed, overhead, CERTIFIRE certificated self-closing device in accordance with the specification below:

Supplier:	Allegion		
Description:	Briton 2420T		
Reference:	Concealed overhead closer		
Certificate:	CF6114		
Material:	Aluminium track and closer body with steel sub-components		
Overall size:	Closer body: 42 mm by 242 mm by 33 mm		
	Track:	15 mm by 440 mm by 23 mm by 2.6 mm	
Position:	Closer body: Fitted within the top edge of the door leaf.		
	Track:	Fitted within the frame head	
Intumescent protection:	Allegion (UK) Ltd, Briton 2420-IP, 2 mm thick intumescent kit covering all faces of the closer body and track case and to the rear of the closer forends.		
Fixings:	Ø4.8 mm by 26 mm – as supplied by the manufacturer		

Alternatively, doorsets shall be fitted with a surface mounted overhead, Certifire certificated selfclosing device from the table below:

Allegion Briton 2130B (CF111)	Dormakaba TS93 (CF119)	Eurospec DCC2024SM (CF5087)
Geze TS2000 NV BC (CF252)	Geze TS3000 (CF145)	Rutland TS.11204 (CF6006)
Rutland TS.3204 (CF6018)	Rutland TS.9205 (CF6144)	Zoo Hardware VDC003 (CF5549)

The exceptions are doors kept locked shut such as service access doors. Note: closers with mechanical hold-open mechanisms are not permitted to be used. Building Regulations may identify locations within domestic locations where self-closing devices are not mandatory.

The closers shall have a power rating appropriate to the leaf sizes, subject to the closer having the ability to close the door from any angle and against any latch and/ or seals fitted. The closer shall have the ability to provide a minimum size 3 closing force.

Closers shall be CE Marked against EN 1154 and categorised as grade 1 – suitable for use on fire/smoke doorsets.

Closers shall be fitted using the fixings supplied by each door closer manufacturer.

14. Ancillary items

Please note that hardware items other than those discussed within this certificate of approval are not permitted.

14a Pull Handles

Not permitted

14b Protection plates and signage

Surface mounted plastic, steel, aluminium, or brass plates are acceptable on the basis that they are:

- < 2mm thick
- Do not occupy more than 20% of the door leaf in total or exceed 500mm in height for kickplates and 300mm for mid-plates, whichever is the smaller.
- Do not wrap around the vertical edges, and on the closing face do not extend beneath the door stops (generally 40-50mm narrower than door width)
- Plates/signage can be bonded with a thermally softening adhesive. Additionally, countersunk screws may be used with maximum dimensions of 4.5 mm Ø by 25 mm long.
- Plates in accordance with the rules above may be applied to one / both door leaf faces as required.

14c Flushbolts

Not permitted

14d. Air transfer grilles

Intumescent protection:

Not permitted

14e. Door Viewers

Joor viewers where required shall be in accordance with the specification below:		
Option 1		
Supplier:	UK Fixings Ltd	
Description:	Door viewer	
Reference:	22528 Silver / Chrome	
Overall dimensions:	Ø13.7 mm by 52 mm (adjustable to leaf thickness)	
Position:	No higher than 1500 mm from the threshold, with a minimum 100 mm	

Door viewers where required shall be in accordance with the specification below:

None required

Option 2		
Supplier:	ERA	
Description:	Door viewer	
Reference:	35053 (6V254) Chrome or 35054 (6V253) Gold	
Overall dimensions:	11.7 mm Ø by 49 mm (adjustable to leaf thickness)	
Position:	No higher than 1500 mm from the bottom of the door leaf, with a	
	minimum 100 mm centre-to-centre between viewers, where a second	
	viewer is required.	
Intumescent protection:	None required	

centre-to-centre between viewers, where a second viewer is required.

14f. Threshold seals

A Lorient Polyproducts Limited LAS8001SI automatic threshold seal shall be fitted centrally in the bottom edge of the door leaf.

14g. Threshold Plates

A Lorient Polyproducts Ltd. LAS4015 aluminium threshold plate with overall dimensions 45 mm wide by 10 mm high shall be fitted / utilised.

Alternatively, a Lorient Polyproducts Ltd. LAS4002 aluminium threshold plate with overall dimensions 40 mm wide by 5 mm high shall be fitted / utilised.

14h. Letter Plates

Letterplates where required shall be in accordance with the specification below:

Supplier:	UAP		
Description:	Soterian Letterplate		
Reference:	UAP Soterian TS008 LP		
Certification ref:	KM670828		
Overall	Aperture size:	230 mm by 35 mm	
dimensions:	Cut out size:	263 mm by 58 mm	
Position:	Letterplates are to be positioned centrally within the leaf width, at a height of 865 mm from the bottom of the door to the centre line of the letterplate.		
Quantity:	Maximum 1No letterplate shall be fitted to each door leaf.		
Orientation	Letterplates are to be installed in a horizontal orientation only.		
Intumescent protection:	1 mm thick graphite intumescent sheet material (supplied with letterplate)		
Fixing:	Four No.6 by 25 mm countersunk wood screws and four M6 by 25 mm hex socket cap bolts.		

14i. Coat Hooks and Other Surface Mounted Hardware

Ancillary items which are wholly surface mounted may be fitted providing:

- These items are screw fixed or bonded only
- Are not bolted through the full thickness of the door
- Are not directly above, or closer than 100 mm to any non-insulated glazing

14j. Electric Strikes / Electromechanical locks

Not permitted

15. Further Information

Further information regarding the details contained in this data sheet may be obtained from JELD-WEN UK Limited (Tel: 0345 122 2891).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).